

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Holdenville did not meet treatment requirements. We routinely monitor your water for Total Organic Carbon (TOC) removal. This tells us whether we are effectively removing Organic Carbon from the water supply. Our latest calculations have shown that we didn't remove the average percentage of organic carbon required by EPA standards during the twelve-month period of October 2016 through September 2017. **What should I do? You do not need to use an alternate water supply or take other actions.** However, if you have specific health concerns consult your doctor. **What does this mean?** Total Organic Carbon has no health effects. However, TOC provides a medium for the formation of disinfection byproducts. These byproducts include Trihalomethanes (THMs) and Haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer. **CORRECTIVE ACTION. What happened? What is being done? When will the violation be resolved?** December 2016, the City completed repairs to the filter and replacement of the media. The plans for the remaining improvements of the Water Treatment Plant (WTP) have been submitted to the State. We have awarded a contract to Walters-Morgan Construction to perform the repairs and improvements. Work includes a second clarifier, re-piping and cleaning of the clearwell, improved instrumentation, and additional piping at the storage tanks to address TTHMs. For further information contact: Oda Jones, WTP Chief Operator (405) 379-2533.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

City of Holdenville, PWSID No.: OK 1020803. CO No: 16-253

Date Distributed: 5-31-2018